

## Public Notice

The Texas Commission on Environmental Quality ("TCEQ") sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain diseases-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Llano failed to meet the minimum treatment technique requirements on 4/17/10. Specifically, our water system allowed the turbidity of the filtered water to exceed 1.0 Nephelometric Turbidity Units.

The treatment technique requirement was unable to be met due to the raw water turbidity of the Llano River during flood conditions. Although the filtered water did not meet the minimum treatment technique requirements, the finished water, which is pumped to the distribution system, never exceeded these requirements. The City of Llano has taken the following corrective actions to prevent a recurrence of the violation: Contracted with Excel Construction Services to have the filter media at the surface water treatment plant replaced.

If you want more information about the nature and significance of this violation, you may contact City of Llano Utilities Office at 325-247-4158.

Please share this information with all the other people who drink the water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

## Aviso público

La Comisión de Texas sobre calidad ambiental ("TCEQ") establece mínimas de agua de normas de calidad para el público de agua potable. Estas normas incluyen requisitos de técnica de tratamiento exigibles para el agua potable. Agua tratada puede contener organismos causantes de enfermedades. Estos organismos son bacterias, virus y parásitos que pueden causar síntomas como náuseas, calambres, diarrea y dolores de cabeza asociados.

La ciudad de Llano ha podido satisfacer los requisitos de la técnica de tratamiento mínimo en 17 de 4 de 10. En concreto, nuestro sistema de agua permitió la turbidez del agua filtrada para superar a 1.0 nefelométrico unidades de turbidez.

El requisito de la técnica de tratamiento no pudo cumplirse debido a la turbidez del agua del río Llano durante condiciones de inundación. Aunque el agua filtrada no cumplía los requisitos de la técnica de tratamiento mínimo, el agua terminado, que se bombea al sistema de distribución, nunca había superado estos requisitos. La ciudad de Llano ha llevado a las siguientes medidas correctivas para evitar una repetición de la violación: contratada con los servicios de construcción de Excel para tener los medios de comunicación de filtro en la planta de tratamiento de agua superficial reemplazada.

Si desea obtener más información acerca de la naturaleza y significado de esta violación, usted puede contactar a ciudad de Llano utilidades Oficina en 325-247-4158.

Por favor comparta esta información con todas las otras personas que beben el agua, especialmente aquellos que no pueden haber recibido este aviso directamente (por ejemplo, personas en apartamentos, residencias, escuelas y empresas). Puede hacerlo mediante la publicación de este aviso en un lugar público o distribuir copias a mano o por correo.